

WG13 Issues - CIM Issues #4093

A few smaller HVDC issues - power factor control is needed

09/14/2021 03:44 PM - Herbert Falk

Status: Closed	
Priority: Normal	
Target version:	
Author/Contact Info: ENTSO-E	Standard(s):
Base Release: 61970cim16v20	Version:
Solution to be Applied To: 61970cim16v21	Clause:
Solution Version: CIM16	Sub-Clause:
Solution Applied By: LOO	Paragraph:
Completion Date: 05/15/2013	Table:
CIM Keywords:	Originally Closed in Version: CIM16
Breaking Change: No	Origination Date: 05/13/2013
Breaking Change Description:	Origination ID: 13_147
CIM Impacted Groups: WG13	Originally Assigned To:
Requestor:	
Description A few smaller HVDC issues - power factor control is needed for qPccControl - directQcontrol is duplicate with qPccControl - Idc in the loss formula shall be an absolute value - the ConverterDCSide cannot exist without the ConverterACSide, make the association mandatory.	
Proposed Solution Update as suggested.	