

WG13 Issues - CIM Issues #4098

Control is assoc. with RegulatingCondEq This makes it impos

09/14/2021 03:44 PM - Herbert Falk

Status: Closed	
Priority: Normal	
Target version:	
Author/Contact Info: Lars-Ola Osterlund	Standard(s):
Base Release: 61970cim16v21	Version:
Solution to be Applied To: 61970cim16v22	Clause:
Solution Version: CIM16	Sub-Clause:
Solution Applied By: LOO	Paragraph:
Completion Date: 05/30/2013	Table:
CIM Keywords:	Originally Closed in Version: CIM16
Breaking Change: No	Origination Date: 05/29/2013
Breaking Change Description:	Origination ID: 13_153
CIM Impacted Groups: WG13	Originally Assigned To:
Requestor:	
Description Control is assoc. with RegulatingCondEq This makes it impossible to control other equipment than RegulatingCondEq, e.g. TapChanger.	
Proposed Solution Change the association Control-RegulatingCondEq to Control-PSR, i.e. the same as for Measurement.	
Decision Changed as suggested.	