WG13 Issues - CIM Issues #4257

The use of EquivalentSource is unclear (it may be a remnant

09/14/2021 03:44 PM - Herbert Falk

Status: Closed

Priority: Normal

Target version:

Base Release:

Author/Contact Info: Lars-Ola Osterlund (cimxml meeting

April 3)

Version:

Clause: Solution to be Applied To:

Solution Version: CIM₁₀ Sub-Clause: Solution Applied By: Paragraph:

Completion Date: Table:

CIM Keywords: **Originally Closed in** CIM₁₀

Version:

Standard(s):

Origination Date: **Breaking Change:** No 04/04/2001

Origination ID: Breaking Change 106 **Description:**

CIM Impacted WG13 **Originally Assigned**

Groups:

To: Requestor:

Description

The use of EquivalentSource is unclear (it may be a remnant from a relic 70ties Load Flow program).

Proposed Solution

Investigate if EquivalentSource can be removed.

Decision

Erich: Needed for distribution applications, when generation details are not available. WG13: Agreed. Leave in for distribution use. 2006-09-19 Closed

05/18/2024 1/1