

WG13 Issues - CIM Issues #4270

ACLineSegment needs reference to BaseVoltage. At the moment

09/14/2021 03:44 PM - Herbert Falk

Status: Closed	
Priority: Normal	
Target version:	
Author/Contact Info: Interop. Test #2 - Areva (Widergren, Fairchild)	Standard(s):
Base Release:	Version:
Solution to be Applied To:	Clause:
Solution Version: CIM10	Sub-Clause:
Solution Applied By:	Paragraph:
Completion Date:	Table:
CIM Keywords:	Originally Closed in Version: CIM10
Breaking Change: No	Origination Date: 04/29/2001
Breaking Change Description:	Origination ID: 138
CIM Impacted Groups: WG13	Originally Assigned To:
Requestor:	
Description ACLineSegment needs reference to BaseVoltage. At the moment, it contains reference MemberOfEquipmentContainer. This showed up in the Duke model import as exported by Siemens.	
Proposed Solution The CPSM profile in Section 3.4.1 ACLineSegment (10 Apr 01) should require BaseVoltage (inherited by Conducting Equipment) and not MemberOf_EquipmentContainer.	
Decision 6/22/2004. Resolved by correcting NERC profile. Not a CIM issue. No change. (Also see issue 132)	