IEC 61850 User Feedback Task Force - Feature #438

The engineering-process is well defined for a green field / new IEC 61850 substation but needs clarification for refurbishment

02/03/2021 02:07 PM - Herbert Falk

Status: Resolved

Priority: Normal

Assignee:

Category: Standard clarification required

Target version:

ID:

Source: Vattenfall

TF Unique ID: 1 # Vattenfall

WG10 Proposal: Answer from Joerg regarding 6-100:For

the brown field engineering, as well as for discussions about IED specification, the understanding of SSD and SCD file needs to be clarified. These files are not defined by their content, but by their role in the Engineering process. Some examples: • A Utility delivers as part of a specification an SCL file with only a Substation Section, even no Data Types: This is an SSD• The System Integrator is lazy and returns a file with only "as

built" IEDs, Data Types and

Communication Section: This is an SCD• A Utility adds a new bay to an existing SCD (brown field). And uses this as specification for the extension of the existing station: This is an SSD- A Utility creates a specification with Substation Section and Virtual IEDs. The Virtual IEDs are completely engineered

(GOOSE, Reports, etc.): This is an SSD• The System Integrator return an identical file, but "as built": This is an SCDUp to now (SCL ED2) the user has to know the meaning of the file. It cannot be derived from the content, 6-100 however is adding some semantics to the File: • An SCL file can have a GUID and a Semantic Version• An SCD can have a reference to the SSD that it implements• Each IED in an SCD can have ola reference to the ISD file, that was specifying ito a reference to the

ICD, IID or CID file it is based on• ☐ Each

virtual IED in an SSD can reference the

ISD file it was specified with.

Ed 3

Estimated Completion:

Meeting:

Discuss in Upcoming No

Start date:

Due date:

% Done: 0%

Estimated time: 0.00 hour

To discuss in WG10: Yes

Short Proposal: Add Part 6 a use case for extension to

Yes

existing system from existing SCD. Add

SICS for specification tool

Standard(s): IEC 61850-4

Needs More Information:

Assigned TF: 61850-4

Description

The engineering-processen is well defined for a green field / new IEC 61850 substation but needs clarification for refurbishment and extensions. In a green field project Vattefall starts by defining the SSD and hands it over to supplier as part of the bid for tender.

04/19/2024 1/2 Clarification of the process for an existing substation is required. Here utility needs to start by extending or modifying an existing SCD substation from original supplier. How are the modified parts of substation section handled? Can a SSD be created that maintains links to existing communication and IED structures, into which a new supplier can continue work? (61850-6:2009 clause 10 needs to define also "specification tool" besides system configurator. Can data flow engineering rights and SED files that be used for this use case?)

History

#1 - 02/11/2021 07:59 AM - Vladan Cvejic

- Subject changed from The engineering-processen is well defined for a green field / new IEC 61850 substation but needs clarification for refurbishment to The engineering-process is well defined for a green field / new IEC 61850 substation but needs clarification for refurbishment
- Status changed from New to In Progress
- Standard(s) set to IEC 61850-6 (-100)
- WG10 Proposal changed from Answer from Joerg regarding 6-100:

For the brown field engineering, as well as for discussions about IED specification, the understanding of SSD and SCD file needs to be clarified. These files are not defined by their content, but by their role in the Engineering process.

Some examples:

- A Utility delivers as part of a specification an SCL file with only a Substation Section, even no Data Types: This is an SSD
- 🖪 The System Integrator is lazy and returns a file with only "as built" IEDs, Data Types and Communication Section: This is an SCD
- A Utility adds a new bay to an existing SCD (brown field). And uses this as specification for the extension of the existing station: This is an SSD
- A Utility creates a specification with Substation Section and Virtual IEDs. The Virtual IEDs are completely engineered (GOOSE, Reports, etc.): This is an SSD
- The System Integrator return an identical file, but "as built": This is an SCD

Up to now (SCL ED2) the user has to know the meaning of the file. It cannot be derived from the content. 6-100 however is adding some semantics to the File:

- An SCL file can have a GUID and a Semantic Version
- An SCD can have a reference to the SSD that it implements
- Each IED in an SCD can have
- oll a reference to the ISD file, that was specifying it
- oll a reference to the ICD, IID or CID file it is based on
- Each virtual IED in an SSD can reference the ISD file it was specified with.

to Answer from Joerg regarding 6-100:For the brown field engineering, as well as for discussions about IED specification, the understanding of SSD and SCD file needs to be clarified. These files are not defined by their content, but by their role in the Engineering process. Some examples: A Utility delivers as part of a specification an SCL file with only a Substation Section, even no Data Types: This is an SSD-1 The System Integrator is lazy and returns a file with only "as built" IEDs, Data Types and Communication Section: This is an SCD-1 A Utility adds a new bay to an existing SCD (brown field). And uses this as specification for the extension of the existing station: This is an SSD-1 A Utility creates a specification with Substation Section and Virtual IEDs. The Virtual IEDs are completely engineered (GOOSE, Reports, etc.): This is an SSD-1 The System Integrator return an identical file, but "as built": This is an SCDUp to now (SCL ED2) the user has to know the meaning of the file. It cannot be derived from the content. 6-100 however is adding some semantics to the File: An SCL file can have a GUID and a Semantic Version-1 An SCD can have a reference to the SSD that it implements-1 Each IED in an SCD can have of a reference to the ISD file, that was specifying ito1 a reference to the ICD, IID or CID file it is based on Each virtual IED in an SSD can reference the ISD file it was specified with.

- Discuss in Upcoming Meeting set to No

Checking done.

#2 - 12/05/2023 07:08 AM - Vladan Cvejic

- Discuss in Upcoming Meeting changed from No to Yes
- To discuss in WG10 set to No
- Needs More Information set to Yes

#3 - 12/05/2023 08:26 AM - Vladan Cvejic

- Status changed from In Progress to Resolved
- Discuss in Upcoming Meeting changed from Yes to No
- To discuss in WG10 changed from No to Yes
- Standard(s) changed from IEC 61850-6 (-100) to IEC 61850-4
- Assigned TF 61850-4 added

Most of the issues are resolved by 90-30 (old 6-100) but rest of the questions should be addressed by part 4 (Ed3). Editor to be determined on the next WG10 meeting.

04/19/2024 2/2