IEC 61850 User Feedback Task Force - Bug #454

Data model: extension of logical nodes with new DOs. Question about namespace.

02/03/2021 02:07 PM - Herbert Falk

Status: Closed

Priority: High

Assignee: Category:

Standard clarification required

Target version:

ID: 11

Source: IOP_2013

TF Unique ID: 11 # IOP 2013

WG10 Proposal: According to Cathedral City meeting (ref.

to UFTF-CathedralMOM20160219) this

issue is closed.

Estimated June 2015 WG10 Meeting

Completion:

Discuss in Upcoming

Meeting:

Start date:

Due date:

% Done: 0%

Estimated time: 0.00 hour

To discuss in WG10:

Short Proposal: The complete handling of name space

attribute is currently under clarification in

WG10.

Standard(s):

Needs More Information:

Assigned TF:

Description

An SCL file was produced that instantiated a new DO within a LN. The DO was from the same 61850-7-4 Namespace. The question that arose was what should be the Logical Node Namespace or Data Namespace.

After discussion, the group tended to lean towards the use of DataNS to indicate this type of LN. However, clarification is needed within the standards.

History

#1 - 02/03/2021 04:00 PM - Herbert Falk

- Priority changed from Normal to High

#2 - 02/05/2021 07:09 AM - Herbert Falk

- Status changed from New to Closed

#3 - 02/09/2021 06:16 AM - Carlos Rodriguez del Castillo

- Subject changed from An SCL file was produced that instantiated a new DO within a LN. The DO was from the same 61850-7-4 Namespace. The question that to Data model: extension of logical nodes with new DOs. Question about namespace.

CRC: I think it is clarified in 7-1 ed2. To confirm with task forcé.

04/19/2024 1/1