

## IEC 61850 User Feedback Task Force - Support #465

In a SCD there were LNodes in the substation section that were not associated to a specific IED/LN instance. In particular, an S

02/03/2021 02:07 PM - Herbert Falk

<b>Status:</b> Closed	<b>Start date:</b>
<b>Priority:</b> Normal	<b>Due date:</b>
<b>Assignee:</b>	<b>% Done:</b> 0%
<b>Category:</b> Solved / Missunderstanding	<b>Estimated time:</b> 0.00 hour
<b>Target version:</b>	<b>To discuss in WG10:</b>
<b>ID:</b> 22 (1)	<b>Short Proposal:</b> Improvement of the schema or clarify the part 6. "null" is not a valid value. It should validate against IED names or "None". Also IED names in the IED section shall not be "None".
<b>Source:</b> IOP_2013	<b>Standard(s):</b>
<b>TF Unique ID:</b> 22 (1) # IOP_2013	<b>Needs More Information:</b>
<b>WG10 Proposal:</b> Tissue 1365	<b>Assigned TF:</b>
<b>Estimated Completion:</b>	
<b>Discuss in Upcoming Meeting:</b>	
<b>Description</b>	
In a SCD there were LNodes in the substation section that were not associated to a specific IED/LN instance. In particular, an SCD file contained an IEDName whose value was "null".	
This file did not import into certain tooling.	

### History

#1 - 06/21/2022 09:00 AM - Carlos Rodriguez del Castillo

- Status changed from New to Closed