

## IEC 61850 User Feedback Task Force - Support #470

An ICT provides an IID/ICD file that defines 4 GOCBs. The SCT imports this file, creates an SCD which has only 1 GOCB. The ICT r

02/03/2021 02:07 PM - Herbert Falk

<b>Status:</b>	Closed	<b>Start date:</b>	
<b>Priority:</b>	Normal	<b>Due date:</b>	
<b>Assignee:</b>		<b>% Done:</b>	0%
<b>Category:</b>	Already captured with TISSUE	<b>Estimated time:</b>	0.00 hour
<b>Target version:</b>		<b>To discuss in WG10:</b>	
<b>ID:</b>	26	<b>Short Proposal:</b>	See Issue #21
<b>Source:</b>	IOP_2013	<b>Standard(s):</b>	
<b>TF Unique ID:</b>	26 # IOP_2013	<b>Needs More Information:</b>	
<b>WG10 Proposal:</b>		<b>Assigned TF:</b>	
<b>Estimated Completion:</b>			
<b>Discuss in Upcoming Meeting:</b>			
<b>Description</b>			
An ICT provides an IID/ICD file that defines 4 GOCBs. The SCT imports this file, creates an SCD which has only 1 GOCB. The ICT refuses to import the SCD as it is expecting 4 GOCBs. At first analysis, the SCT should not remove the configured GOCBs. However, this is an issue that needs further clarification.			

### History

#1 - 06/21/2022 09:00 AM - Carlos Rodriguez del Castillo

- Status changed from New to Closed