

IEC 61850 User Feedback Task Force - Support #474

Should all SCTs support a substation section and the ability to associate LNodes into that section.

02/03/2021 02:07 PM - Herbert Falk

Status: Closed	Start date:
Priority: Normal	Due date:
Assignee:	% Done: 0%
Category: Solved / Missunderstanding	Estimated time: 0.00 hour
Target version:	To discuss in WG10:
ID: 30	Short Proposal: Part 6 Ed.2 mandates a substation section in the SCD file. All the rest, editing the substation section, layout coordinates and LNode binding is optional (SICS S41 - S48) and is the plus value a vendor can add to its products.
Source: IOP_2013	Standard(s):
TF Unique ID: 30 # IOP_2013	Needs More Information:
WG10 Proposal:	Assigned TF:
Estimated Completion:	
Discuss in Upcoming Meeting:	
Description Should all SCTs support a substation section and the ability to associate LNodes into that section.	

History

#1 - 06/21/2022 09:00 AM - Carlos Rodriguez del Castillo

- Status changed from New to Closed