

## IEC 61850 User Feedback Task Force - Support #476

**Currently, in SCL, the size of an array is numeric. This could lead to issues of consistency (e.g. one having 32 array elements**

02/03/2021 02:07 PM - Herbert Falk

<b>Status:</b> Closed	<b>Start date:</b>
<b>Priority:</b> Normal	<b>Due date:</b>
<b>Assignee:</b>	<b>% Done:</b> 0%
<b>Category:</b>	<b>Estimated time:</b> 0.00 hour
<b>Target version:</b>	<b>To discuss in WG10:</b>
<b>ID:</b> 32	<b>Short Proposal:</b> unsure of problem, each phase array of an object of type HDEL has same length.
<b>Source:</b> IOP_2013	<b>Standard(s):</b>
<b>TF Unique ID:</b> 32 # IOP_2013	<b>Needs More Information:</b>
<b>WG10 Proposal:</b> Addressed with Ed2	<b>Assigned TF:</b>
<b>Estimated Completion:</b>	
<b>Discuss in Upcoming Meeting:</b>	
<b>Description</b> Currently, in SCL, the size of an array is numeric. This could lead to issues of consistency (e.g. one having 32 array elements and the other 33). This is not allowed in CDCs such as HDEL. It is suggested that some mechanism be developed to use a single value instead of multiple integers.	

### History

#1 - 06/21/2022 09:00 AM - Carlos Rodriguez del Castillo

- Status changed from New to Closed