

WG13 Issues - CIM Issues #4778

normal status on PSR

ShuntCompensator - normalStatus on PSR

09/14/2021 03:46 PM - Herbert Falk

Status:	Closed	
Priority:	Normal	
Target version:		
Author/Contact Info:	wg 13 - CIM for Planning - by Kendall Demaree	Standard(s):
Base Release:		Version:
Solution to be Applied To:	13	Clause:
Solution Version:	CIM11	Sub-Clause:
Solution Applied By:		Paragraph:
Completion Date:		Table:
CIM Keywords:		Originally Closed in Version: CIM11
Breaking Change:	No	Origination Date: 01/29/2008
Breaking Change Description:		Origination ID: 713
CIM Impacted Groups:	WG13	Originally Assigned To:
Requestor:		
Description normal status on PSR ShuntCompensator - normalStatus on PSR maps to normal in service (not specific to planning), ActivityRecord maps to actual status.		
Proposed Solution Nothing here is specific to planning and the existing. PSRStatus is using only a string as the status which seems unclear how to use. Planning added normalStatus:String to PSR. Used for operations and for planning.		
Decision New attribute on Equipment. "normallyInService" - boolean 4/16/2008 Description needs be made. In the absense of breaker models this is used to disconnect the device from the network.		