

WG13 Issues - CIM Issues #4916

documentation on VoltageControlZone is wrong. This may hav

09/14/2021 03:47 PM - Herbert Falk

<b>Status:</b>	Closed	
<b>Priority:</b>	Normal	
<b>Target version:</b>		
<b>Author/Contact Info:</b>	Kendall Demaree	<b>Standard(s):</b>
<b>Base Release:</b>	IEC61970CIM13r08	<b>Version:</b>
<b>Solution to be Applied To:</b>	CIM18v10	<b>Clause:</b>
<b>Solution Version:</b>	CIM18v10	<b>Sub-Clause:</b>
<b>Solution Applied By:</b>	Chavdar Ivanov	<b>Paragraph:</b>
<b>Completion Date:</b>	02/04/2024	<b>Table:</b>
<b>CIM Keywords:</b>	61970-Wires	<b>Originally Closed in Version:</b>
<b>Breaking Change:</b>	No	<b>Origination Date:</b> 07/14/2008
<b>Breaking Change Description:</b>		<b>Origination ID:</b> 919
<b>CIM Impacted Groups:</b>	WG13	<b>Originally Assigned To:</b>
<b>Requestor:</b>		
<b>Description</b>		
documentation on VoltageControlZone is wrong. This may have been replaced by the RegulationControl class, but we need discussion.		
<b>Proposed Solution</b>		
.Need to identify someone who can check and correct this description.		
<b>Decision</b>		
Oslo 14 June 2023 Deprecate the class		
<b>Release Notes</b>		
Deprecated class VoltageControlZone		

History

#1 - 02/07/2023 11:34 AM - Chavdar Ivanov

- Status changed from Open to Review
- Priority changed from Low to Normal
- Base Release changed from IEC61970CIM13r08 to IEC61970CIM13r08

The current description is

An area of the power system network which is defined for secondary voltage control purposes. A voltage control zone consists of a collection of substations with a designated bus bar section whose voltage will be controlled.

Indeed it does not look so good as there is no association to Substation so it is hard to imagine it is collection of substations. This class is not used in 452. We can fix the description a bit and close the issue or even deprecate the class if this is not going to be used.

#2 - 06/14/2023 10:08 AM - Chavdar Ivanov

- Decision updated

#3 - 02/04/2024 02:04 AM - Chavdar Ivanov

- Status changed from Review to Closed

- *Solution to be Applied To* set to *CIM18v10*
- *Solution Version* set to *CIM18v10*
- *Solution Applied By* set to *Chavdar Ivanov*
- *Completion Date* set to *02/04/2024*
- *Release Notes* updated
- *CIM Keywords* *61970-Wires* added