

## WG13 Issues - CIM Issues #4924

### StaticVarCompensator sign confusion of reactianceThere is

09/14/2021 03:47 PM - Herbert Falk

<b>Status:</b> Closed	
<b>Priority:</b> Low	
<b>Target version:</b>	
<b>Author/Contact Info:</b> Kendall Demaree for Chuck Dubose	<b>Standard(s):</b>
<b>Base Release:</b> 61970cim15v31	<b>Version:</b>
<b>Solution to be Applied To:</b> 61970cim16	<b>Clause:</b>
<b>Solution Version:</b>	<b>Sub-Clause:</b>
<b>Solution Applied By:</b>	<b>Paragraph:</b>
<b>Completion Date:</b>	<b>Table:</b>
<b>CIM Keywords:</b>	<b>Originally Closed in Version:</b>
<b>Breaking Change:</b> No	<b>Origination Date:</b> 08/09/2011
<b>Breaking Change Description:</b>	<b>Origination ID:</b> 13_78
<b>CIM Impacted Groups:</b> WG13	<b>Originally Assigned To:</b>
<b>Requestor:</b>	
<b>Description</b> StaticVarCompensator sign confusion of reactiance There is confusion about the sign of the inductiveRating attribute.	
<b>Proposed Solution</b> Clarify.	

#### History

##### #1 - 02/07/2023 11:58 AM - Chavdar Ivanov

- Subject changed from StaticVarCompensator sign confusion of reactiance There is to StaticVarCompensator sign confusion of reactianceThere is
- Status changed from Open to In Progress
- Base Release changed from 61970cim15v31 to 61970cim15v31

It seems signs were changed. The attributes in CIM17 indicate which is positive value and which negative, Therefore the issues is considered closed.

##### #2 - 02/07/2023 11:58 AM - Chavdar Ivanov

- Status changed from In Progress to Closed