

IEC 61850 User Feedback Task Force - Support #493

An icd/iid file is not required to include the “original SCL” element.
Is it required to be added to the IED instance in the SCD

02/03/2021 02:07 PM - Herbert Falk

Status: Closed	Start date:
Priority: Normal	Due date:
Assignee:	% Done: 0%
Category:	Estimated time: 0.00 hour
Target version:	To discuss in WG10:
ID: 8	Short Proposal: TISSUE to be posted by xxx, referring to 1398; make it clear that: - ICD (Ed. 2 or later) shall set originalScIxxx attributes - SCT shall set originalScIxxx attributes on importing an IxD file without originalScIxxx attributes according to the version of the SCL file Add rule that for an IxD file, the originalScIxxx values shall match the SCL version/revision/release.
Source: IOP_2015	Standard(s): 6
TF Unique ID: 8 # IOP_2015	Needs More Information:
WG10 Proposal: TISSUE 1450	Assigned TF:
Estimated Completion:	
Discuss in Upcoming Meeting:	
Description An icd/iid file is not required to include the “original SCL” element. Is it required to be added to the IED instance in the SCD file by the SCT in any case or is it sufficient to be added only if different from version referred to in namespace of the SCD?	

History

#1 - 06/21/2022 09:12 AM - Carlos Rodriguez del Castillo

- Status changed from New to Closed

Confirm to IEC 61850-6 editor that this issue has been accounted for.