

WG13 Issues - CIM Issues #4930

ENTSO-E 13 - EquivalentInjection support WardEquivalentInj

09/14/2021 03:47 PM - Herbert Falk

Status: Closed	
Priority: Low	
Target version:	
Author/Contact Info: ENTSO-E	Standard(s):
Base Release: 61970cim15v28	Version:
Solution to be Applied To: 61970cim16	Clause:
Solution Version: CIM17	Sub-Clause:
Solution Applied By:	Paragraph:
Completion Date:	Table:
CIM Keywords:	Originally Closed in Version:
Breaking Change: No	Origination Date: 08/17/2011
Breaking Change Description:	Origination ID: 13_91
CIM Impacted Groups: WG13	Originally Assigned To:
Requestor:	
Description ENTSO-E 13 - EquivalentInjection support Ward EquivalentInjeciton should be able to represent extended Ward.	
Proposed Solution Need to deterine the exact needs here.	

History

#1 - 02/07/2023 01:20 PM - Chavdar Ivanov

- Subject changed from ENTSO-E 13 - EquivalentInjection support Ward EquivalentInj to ENTSO-E 13 - EquivalentInjection support WardEquivalentInj
- Status changed from Open to In Progress
- Base Release changed from 61970cim15v28 to 61970cim15v28

#2 - 02/07/2023 01:22 PM - Chavdar Ivanov

- Status changed from In Progress to Closed
- Solution Version set to CIM17

Regulation related attributes and association to ReactiveCapabilityCurve were added in either CIM16 or CIM17. This enables modelling of extended ward.
Therefore I am closing the issue.