WG13 Issues - CIM Issues #4930

ENTSO-E 13 - EquivalentInjection support WardEquivalentInj

09/14/2021 03:47 PM - Herbert Falk

Status:	Closed		
Priority:	Low		
Target version:			
Author/Contact Info:	ENTSO-E	**Standard(s):**	
Base Release:	61970cim15v28	**Version:**	
Solution to be Applied To:	61970cim16	**Clause:**	
Solution Version:	CIM17	**Sub-Clause:**	
Solution Applied By:		**Paragraph:**	
Completion Date:		**Table:**	
CIM Keywords:		**Originally Closed in Version:**	
Breaking Change:	No	**Origination Date:**	08/17/2011
Breaking Change Description:		**Origination ID:**	13_91
CIM Impacted Groups:	WG13	**Originally Assigned To:**	
Requestor:			

Description

ENTSO-E 13 - EquivalentInjection support Ward
EquivalentInjeciton should be able to represent extended Ward.

Proposed Solution

Need to deterine the exact needs here.

History

#1 - 02/07/2023 01:20 PM - Chavdar Ivanov

- Subject changed from ENTSO-E 13 - EquivalentInjection support Ward EquivalentInj to ENTSO-E 13 - EquivalentInjection support WardEquivalentInj

- Status changed from Open to In Progress

- Base Release changed from 61970cim15v28 to 61970cim15v28

#2 - 02/07/2023 01:22 PM - Chavdar Ivanov

- Status changed from In Progress to Closed

- Solution Version set to CIM17

Regulation related attributes and association to ReactiveCapabilityCurve were added in either CIM16 or CIM17. This enables modelling of extended ward.
Therefore I am closing the issue.