

WG13 Issues - CIM Issues #4931

Specification of equipment for network analysisIt is commo

09/14/2021 03:47 PM - Herbert Falk

Status: Closed	
Priority: Low	
Target version:	
Author/Contact Info: Kendall Demaree	Standard(s):
Base Release: 61970cim15v33	Version:
Solution to be Applied To:	Clause:
Solution Version: CIM17	Sub-Clause:
Solution Applied By:	Paragraph:
Completion Date:	Table:
CIM Keywords:	Originally Closed in Version:
Breaking Change: No	Origination Date: 09/21/2011
Breaking Change Description:	Origination ID: 13_98
CIM Impacted Groups: WG13	Originally Assigned To:
Requestor:	
Description Specification of equipment for network analysis It is common for systems to model equipment for SCADA purposes but desire to skip the equipment for use in network analysis.	
Proposed Solution Add an attribute such as "forNetwork" or "forEnergyManagementSystem" to indicate the equipment is to be utilized in the network analysis.	
Decision Related issue 13_161. Svein will start on a white paper, Jay and Lars-Ola will contribute. 2013-06-05/LOO Update Feb 2023 Chavdar: CIM17 includes Equipment.networkAnalysisEnabled: The equipment is enabled to participate in network analysis. If unspecified, the value is assumed to be true.	

History

#1 - 02/07/2023 01:25 PM - Chavdar Ivanov

- Subject changed from Specification of equipment for network analysis
It is commo to Specification of equipment for network analysisIt is commo
- Status changed from Open to In Progress
- Base Release changed from 61970cim15v33
to 61970cim15v33
- Solution Version set to CIM17
- Decision updated

CIM17 includes an attribute to mark Equipment for network analysis. Therefore I am closing the issue.

#2 - 02/07/2023 01:25 PM - Chavdar Ivanov

- Status changed from In Progress to Closed