

WG13 Issues - CIM Issues #4932

Scheduled generation splitSpecify how the scheduled genera

09/14/2021 03:47 PM - Herbert Falk

Status: Closed	
Priority: Low	
Target version:	
Author/Contact Info: Kendall Demaree	Standard(s):
Base Release: 61970cim15v33	Version:
Solution to be Applied To:	Clause:
Solution Version:	Sub-Clause:
Solution Applied By:	Paragraph:
Completion Date: 10/03/2023	Table:
CIM Keywords:	Originally Closed in Version:
Breaking Change: No	Origination Date: 10/27/2011
Breaking Change Description:	Origination ID: 13_103
CIM Impacted Groups: WG13	Originally Assigned To:
Requestor:	
Description Scheduled generation split Specify how the scheduled generation from a market system might be split into actual units within an energy management system.	
Proposed Solution Existing proposal exists. Need to dig this up from old emails. Suggestion is to add a new class where the market value would be input and then model classes to split the signal out to specific GeneratingUnits by a percentage. Check with RegisteredResource in 62325. 2013-09-17/LOO	
Decision Oslo, 14 June 2023 Close the issue Call 23 Aug 2023 Decided to close the issue after 2 weeks review	

History

#1 - 02/07/2023 01:27 PM - Chavdar Ivanov

- Subject changed from Scheduled generation splitSpecify how the scheduled genera to Scheduled generation splitSpecify how the scheduled genera
- Status changed from Open to Review
- Base Release changed from 61970cim15v33 to 61970cim15v33
- Proposed Solution updated

Propose to close this issue as the proposed extensions for schedules and generation shift keys would cover this.

#2 - 06/14/2023 09:59 AM - Chavdar Ivanov

- Decision updated

#3 - 10/03/2023 03:23 AM - Chavdar Ivanov

- Status changed from Review to Closed
- Completion Date set to 10/03/2023
- Decision updated