

## WG13 Issues - CIM Issues #4940

### Outage model for HVDC

### Which HVDC equipment need to be descr

09/14/2021 03:47 PM - Herbert Falk

<b>Status:</b> Open	
<b>Priority:</b> Low	
<b>Target version:</b>	
<b>Author/Contact Info:</b> ENTSO-E	<b>Standard(s):</b>
<b>Base Release:</b> 61970cim16v20	<b>Version:</b>
<b>Solution to be Applied To:</b>	<b>Clause:</b>
<b>Solution Version:</b>	<b>Sub-Clause:</b>
<b>Solution Applied By:</b>	<b>Paragraph:</b>
<b>Completion Date:</b>	<b>Table:</b>
<b>CIM Keywords:</b>	<b>Originally Closed in Version:</b>
<b>Breaking Change:</b> No	<b>Origination Date:</b> 05/13/2013
<b>Breaking Change Description:</b>	<b>Origination ID:</b> 13_150
<b>CIM Impacted Groups:</b> WG13	<b>Originally Assigned To:</b>
<b>Requestor:</b>	
<b>Description</b> Outage model for HVDC Which HVDC equipment need to be described as outaged?	
<b>Decision</b> Discussed 2013-06-05, expanded into a general discussion on inService/LOO	