

## WG13 Issues - CIM Issues #4944

### Combining bus-branch and breaker-nodemodels is unclear. Th

09/14/2021 03:47 PM - Herbert Falk

<b>Status:</b> Closed	
<b>Priority:</b> Low	
<b>Target version:</b>	
<b>Author/Contact Info:</b> WG13	<b>Standard(s):</b>
<b>Base Release:</b> 61970cim16v21	<b>Version:</b>
<b>Solution to be Applied To:</b>	<b>Clause:</b>
<b>Solution Version:</b>	<b>Sub-Clause:</b>
<b>Solution Applied By:</b>	<b>Paragraph:</b>
<b>Completion Date:</b>	<b>Table:</b>
<b>CIM Keywords:</b>	<b>Originally Closed in Version:</b>
<b>Breaking Change:</b> No	<b>Origination Date:</b> 06/05/2013
<b>Breaking Change Description:</b>	<b>Origination ID:</b> 13_172
<b>CIM Impacted Groups:</b> WG13	<b>Originally Assigned To:</b>
<b>Requestor:</b>	
<b>Description</b> Combining bus-branch and breaker-node models is unclear. The following need to be clarified - the use of Terminal.connected vs Switch.open - retained bus coupler switches status for combined models.	

#### History

##### #1 - 02/07/2023 01:56 PM - Chavdar Ivanov

- Subject changed from Combining bus-branch and breaker-node models is unclear. Th to Combining bus-branch and breaker-nodemodels is unclear. Th
- Status changed from Open to In Progress

This was all clarified in CIM17. Therefore I am closing the issue.

##### #2 - 02/07/2023 01:57 PM - Chavdar Ivanov

- Status changed from In Progress to Closed