

## IEC 61850 User Feedback Task Force - Support #499

### Issue 4 – Private section – namespace moved from SCL node to Private nodes ICT added the namespace within the privates instead o

02/03/2021 02:07 PM - Herbert Falk

<b>Status:</b> Closed	<b>Start date:</b>
<b>Priority:</b> Normal	<b>Due date:</b>
<b>Assignee:</b>	<b>% Done:</b> 0%
<b>Category:</b>	<b>Estimated time:</b> 0.00 hour
<b>Target version:</b>	
<b>ID:</b> 14	<b>To discuss in WG10:</b>
<b>Source:</b> IOP_2015	<b>Short Proposal:</b> WG10 to analyze the example and determine if it is allowed or not. Example IID/SCD/SCD to be provided.
<b>TF Unique ID:</b> 14 # IOP_2015	<b>Standard(s):</b> 6
<b>WG10 Proposal:</b> Explanation added into part 6 ed 2.1	<b>Needs More Information:</b>
<b>Estimated Completion:</b>	<b>Assigned TF:</b>
<b>Discuss in Upcoming Meeting:</b>	
<b>Description</b>	
Issue 4 – Private section – namespace moved from SCL node to Private nodes ICT added the namespace within the privates instead of keeping them within the SCL top node. It leads to issues during IID update in SCT.	

#### History

#1 - 06/21/2022 09:12 AM - Carlos Rodriguez del Castillo

- Status changed from New to Closed

Confirm to IEC 61850-6 editor that this issue has been accounted for.