

WG13 Issues - CIM Issues #5016

OperationalLimit for BranchGroupNeed a means to apply the

09/14/2021 03:47 PM - Herbert Falk

Status:	Open	
Priority:	Normal	
Target version:		
Author/Contact Info:	Kendall Demaree	Standard(s):
Base Release:	CIM16	Version:
Solution to be Applied To:		Clause:
Solution Version:		Sub-Clause:
Solution Applied By:		Paragraph:
Completion Date:		Table:
CIM Keywords:		Originally Closed in Version:
Breaking Change:	No	Origination Date: 10/18/2016
Breaking Change Description:		Origination ID: 13_270
CIM Impacted Groups:	WG13	Originally Assigned To:
Requestor:		

Description

OperationalLimit for BranchGroup
Need a means to apply the general operational limit capabilities to BranchGroup rather than the fixed limit attributes on the BranchGroup class.

Proposed Solution

Suggest adding another optional association from OperationalLimitSet to BranchGroup. The direction on OperationalLimit type supplies the direction of flow relative to the BranchGroupTerminal direction.

Assign to Energy Model Requirements Subgroup

For additional information:
<https://github.com/CIMMug-org/WG13InformationModel/issues/9>

History

#1 - 09/14/2021 06:28 PM - Eric Stephan

- Subject changed from OperationalLimit for BranchGroup
Need a means to apply the to OperationalLimit for BranchGroupNeed a means to apply the
- Decision updated

#2 - 12/01/2021 11:43 AM - Eric Stephan

- Proposed Solution updated
- Decision updated

#3 - 01/26/2022 10:32 AM - Svein Olsen

- Proposed Solution updated