

IEC 61850 User Feedback Task Force - Support #504

When IID file from ICT includes "mustUnderstand" attribute in <GSEcontrol> such as <GSEControl desc="System Logical Device GOOS

02/03/2021 02:07 PM - Herbert Falk

Status:	Closed	Start date:	
Priority:	Normal	Due date:	
Assignee:		% Done:	0%
Category:		Estimated time:	0.00 hour
Target version:		To discuss in WG10:	
ID:	19	Short Proposal:	(2015-10-15): Thierry, Camille, Chris The order of elements in SCL is clearly defined in the SCL schema, so no additional clarification is needed. Nonetheless, Part 6 should include an example showing the usage of the mustUnderstand attribute (with GSEControl/Protocol) for clarification.
Source:	IOP_2015	Standard(s):	6
TF Unique ID:	19 # IOP_2015	Needs More Information:	
WG10 Proposal:	it was done CDV amendment 2.1 part 6	Assigned TF:	
Estimated Completion:			
Discuss in Upcoming Meeting:			

Description

When IID file from ICT includes "mustUnderstand" attribute in <GSEcontrol> such as
<GSEControl desc="System Logical Device GOOSE Control Block 1" name="gcb01" datSet="ds_gcb1" confRev="10000" applID="AA1D1Q01KF1System/LLN0gcb01">
<Protocol mustUnderstand="true" />
</GSEControl>

where is the proper order to add <IEDName> attribute? Prior to it, or the next to it? In general case, bottom or top? If tool checks the appropriate attribute order according to schema, it could be issue.

History

#1 - 06/21/2022 09:12 AM - Carlos Rodriguez del Castillo

- Status changed from New to Closed

Confirm to IEC 61850-6 editor that this issue has been accounted for.