

## IEC 61850 User Feedback Task Force - Support #505

**Statement: an SCT A export an SED file with engineering rights “fix” and expectation was SCT B could add Goose clients after imp**

02/03/2021 02:07 PM - Herbert Falk

<b>Status:</b> Closed	<b>Start date:</b>
<b>Priority:</b> Normal	<b>Due date:</b>
<b>Assignee:</b>	<b>% Done:</b> 0%
<b>Category:</b>	<b>Estimated time:</b> 0.00 hour
<b>Target version:</b>	<b>To discuss in WG10:</b>
<b>ID:</b> 20	<b>Short Proposal:</b> (2015-10-15): Thierry, Camille, Chris Even if engRight=fix you are allowed to add subscriber/client information.
<b>Source:</b> IOP_2015	<b>Standard(s):</b> 6
<b>TF Unique ID:</b> 20 # IOP_2015	<b>Needs More Information:</b>
<b>WG10 Proposal:</b> it was done CDV amendment 2.1 part 6	<b>Assigned TF:</b>
<b>Estimated Completion:</b>	
<b>Discuss in Upcoming Meeting:</b>	
<b>Description</b>	
Statement: an SCT A export an SED file with engineering rights “fix” and expectation was SCT B could add Goose clients after importing SED file from SCT A. Result: SCT B IS not allowing goose client cause by the engineering rights “fix”	
1- A precision is require in the standard, Is the “Fix” tag means also that is not allowed to add client to a goose from an IED already engineered by the first SCT?? 2- When the engineering rights is “fix” export a SED file should by restrictive down to the minimum ?	

### History

#1 - 06/21/2022 09:12 AM - Carlos Rodriguez del Castillo

- Status changed from New to Closed

Confirm to IEC 61850-6 editor that this issue has been accounted for.