

IEC 61850 Certificate - IEC 61850 Certificate #5069

Easergy MiCOM P139 [Schneider Electric Industries SAS]

09/15/2021 12:13 PM - Bruce Muschlitz

Status:	Approved	Test Document:	
Priority:	Normal	Certificate Name:	10299662-INC 21-3106
61850 Edition:	Edition 2	Certificate Hash:	E37A9B327BB8AE676B2633A67BE14D 65C4BB081536F0B5FCD1EA2EF1D39 B80B4
61850 Tested Aspects:	Server	Vendor Artifact File Name:	
Company:	Schneider Electric Industries SAS	Vendor Artifact Hash:	
Address:	35 rue Joseph Monier 92500 Rueil Malmaison France	Umbrella Organization:	Schneider
Product:	Easergy MiCOM P139	Optional Reservation Test:	No
HW Version:	974	Serial Number:	
SW Version:	P139-672-701-256	Publisher Legacy Variants:	
Key Words:	Bay Controller, IOC, Protection, Relay, TOC	Publisher Preferred Rates:	
Test Procedure Version:		Publisher Preferred Variants:	
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Sets (B2), Direct Control (12a), Enhanced Direct Control (12c), Enhanced SBO Control (12d), File Transfer (B14), GOOSE Publish (9a), GOOSE Subscribe (9b), SBO Control (12b), Setting Group (B4), Time Synchronization (B13), Unbuffered Reporting (B5)	Subscriber Legacy Variants:	
Certificate/Result Reviewer:	Bruce.Muschlitz	Subscriber Preferred Variants:	
Approval Date:	07/12/2021	Subscriber Preferred Rates:	
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
Current Test Lab Name:	DNV Netherlands (A)		
Description			
Feeder Management Protection and Bay Control			

Files

21-3106_DNV_Schneider_P139_ServerEd2_Certificate.pdf	118 KB	09/15/2021	Bruce Muschlitz
--	--------	------------	-----------------