

IEC 61850 Certificate - IEC 61850 Certificate #5070

Easergy MiCOM P546 [Schneider Electric Industries SAS]

09/15/2021 12:35 PM - Bruce Muschlitz

Status:	Approved	Test Document:	
Priority:	Normal	Certificate Name:	10299662-INC 21-3112
61850 Edition:	Edition 2	Certificate Hash:	5D0F2EAF780567079201A521C6E817B 71F52768C6C2F2962606F19B045AA62 F8
61850 Tested Aspects:	Server	Vendor Artifact File Name:	
Company:	Schneider Electric Industries SAS	Vendor Artifact Hash:	
Address:	35 rue Joseph Monier 92500 Rueil Malmaison France	Umbrella Organization:	Schneider
Product:	Easergy MiCOM P546	Optional Reservation Test:	No
HW Version:	M	Serial Number:	
SW Version:	K3	Publisher Legacy Variants:	
Key Words:	Differential, Protection, Relay	Publisher Preferred Rates:	
Test Procedure Version:		Publisher Preferred Variants:	
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Sets (B2), Direct Control (12a), Enhanced Direct Control (12c), Enhanced SBO Control (12d), File Transfer (B14), GOOSE Publish (9a), GOOSE Subscribe (9b), SBO Control (12b), Setting Group (B4), Time Synchronization (B13), Unbuffered Reporting (B5)	Subscriber Legacy Variants:	
Certificate/Result Reviewer:	Bruce.Muschlitz	Subscriber Preferred Variants:	
Approval Date:	07/22/2021	Subscriber Preferred Rates:	
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
Current Test Lab Name:	DNV Netherlands (A)		
Description			
Line Differential Protection Relay			

Files

21-3112_DNV_Schneider_P546_ServerEd2_Certificate.pdf	118 KB	09/15/2021	Bruce Muschlitz
--	--------	------------	-----------------