IEC 61850 Certificate - IEC 61850 Certificate #5070

Easergy MiCOM P546 [Schneider Electric Industries SAS]

09/15/2021 12:35 PM - Bruce Muschlitz

Status:	Approved		
Priority:	Normal		
61850 Edition:	Edition 2	**Certificate Name:**	10299662-INC 21-3112
61850 Tested Aspects:	Server	**Certificate Hash:**	5D0F2EAF780567079201A521C6E817B71F52768C6C2F2962606F19B045AA62F8
Company:	Schneider Electric Industries SAS	**Vendor Artifact File Name:**	
Address:	35 rue Joseph Monier 92500 Rueil Malmaison France	**Vendor Artifact Hash:**	
Product:	Easergy MiCOM P546	**Umbrella Organization:**	Schneider
HW Version:	M	**Optional Reservation Test:**	No
SW Version:	K3	**Serial Number:**	
Key Words:	Differential, Protection, Relay	**Publisher Legacy Variants:**	
Test Procedure Version:		**Publisher Preferred Rates:**	
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Sets (B2), Direct Control (12a), Enhanced Direct Control (12c), Enhanced SBO Control (12d), File Transfer (B14), GOOSE Publish (9a), GOOSE Subscribe (9b), SBO Control (12b), Setting Group (B4), Time Synchronization (B13), Unbuffered Reporting (B5)	**Publisher Preferred Variants:**	
Certificate/Result Reviewer:	Bruce.Muschlitz	**Subscriber Legacy Variants:**	
Approval Date:	07/22/2021	**Subscriber Preferred Variants:**	
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1	**Subscriber Preferred Rates:**	
Current Test Lab Name:	DNV Netherlands (A)	**Product Variants:**	
Test Document:			

Description

Line Differential Protection Relay

Files

21-3112_DNV_Schneider_P546_ServerEd2_Certificate.pdf	118 KB	09/15/2021	Bruce Muschlitz