

IEC 61850 Certificate - IEC 61850 Certificate #5071

ENCS-3m.648-1-3 [Engineering Center Energoservice]

09/15/2021 01:05 PM - Bruce Muschlitz

Status:	Approved	Test Document:	
Priority:	Normal	Certificate Name:	10300969-INC 21-3227
61850 Edition:	Edition 2	Certificate Hash:	CCCE560EE16F9805EEE328498A2390 A263E016D35669A7DDF5F0D9637CC6 D5FC
61850 Tested Aspects:	Server	Vendor Artifact File Name:	
Company:	Engineering Center Energoservice	Vendor Artifact Hash:	
Address:	44, Aviamotornaya street, Bld 1 Office 1A, Room 1 Moscow, 111024 Russian Federation	Umbrella Organization:	Energoservice
Product:	ENCS-3m.648-1-3	Optional Reservation Test:	No
HW Version:		Serial Number:	
SW Version:	1.4.7	Publisher Legacy Variants:	
Key Words:	Meter, RTU	Publisher Preferred Rates:	
Test Procedure Version:		Publisher Preferred Variants:	
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Set Definition (B2+), Data Sets (B2), Direct Control (12a), Enhanced Direct Control (12c), Enhanced SBO Control (12d), GOOSE Publish (9a), GOOSE Subscribe (9b), SBO Control (12b), Time Synchronization (B13), Unbuffered Reporting (B5)	Subscriber Legacy Variants:	
Certificate/Result Reviewer:	Bruce.Muschlitz	Subscriber Preferred Variants:	
Approval Date:	09/07/2021	Subscriber Preferred Rates:	
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
Current Test Lab Name:	DNV Netherlands (A)		
Description			
Remote terminal unit With Smart meter ESM and IO Module ENMV-1			

History

#1 - 09/15/2021 01:06 PM - Bruce Muschlitz

- File 21-3227_DNV_ENERGOSERVICE_ENCS-3_ServerEd2_Certificate.pdf added

Files

21-3227_DNV_ENERGOSERVICE_ENCS-3_ServerEd2_Certificate.pdf 33 KB

09/15/2021

Bruce Muschlitz