

IEC 61850 User Feedback Task Force - Feature #5078

Clarification on the ctlModel 1/3

09/20/2021 08:27 AM - Carlos Rodriguez del Castillo

Status:	Resolved	Start date:	09/20/2021
Priority:	Normal	Due date:	01/20/2022
Assignee:		% Done:	0%
Category:	Standard clarification required	Estimated time:	0.00 hour
Target version:		To discuss in WG10:	No
ID:	2	Short Proposal:	
Source:	MH	Standard(s):	IEC 61850-7-1 / 7-2 Ed2.1 / 7-5/7-500
TF Unique ID:	2 # MH	Needs More Information:	No
WG10 Proposal:		Assigned TF:	
Estimated Completion:			
Discuss in Upcoming Meeting:	No		
Description			
What is the purpose of 'ctlModel' at X group level, Y group level respectively? Operator switchgear controls are managed by CSWI LN, so a Select to allow the operator to think twice before Operate is not needed on X group level.			
Proposal descriptions			
WG 10 needs to decide which task force needs to take a look at all the parts and determine the best approach as to where the clarification(s) needs to be made.			
Related issues:			
Related to IEC 61850 User Feedback Task Force - Feature #5079: Clarification ...		Resolved	09/20/2021 01/20/2022
Related to IEC 61850 User Feedback Task Force - Feature #5080: Clarification ...		Resolved	09/20/2021 01/20/2022
Copied to 61850-7-5 and 61850-7-500 - IEC61850-7-5 #6382: Clarification on th...		New	09/20/2021 01/20/2022

History

#1 - 11/23/2021 09:10 AM - Carlos Rodriguez del Castillo

- Status changed from New to Triage

Should XCBB (for instance) ctlModel equals to CSWI ctlModel?
ATCC - YLTC? The same?

Action item: Send the question to 7-500 to get more information.

#2 - 02/01/2022 08:53 AM - Vladan Cvejic

- Related to Feature #5079: Clarification on the ctlModel 2/3 added

#3 - 02/01/2022 08:53 AM - Vladan Cvejic

- Related to Feature #5080: Clarification on the ctlModel 3/3 added

#4 - 02/01/2022 08:53 AM - Vladan Cvejic

- Proposal descriptions updated

- To discuss in WG10 changed from No to Yes

#5 - 02/09/2022 07:11 AM - Vladan Cvejic

- Status changed from Triage to Resolved

- Discuss in Upcoming Meeting changed from Yes to No

- To discuss in WG10 changed from Yes to No

- Standard(s) changed from IEC 61850-7-1 / 7-2 Ed2.1 to IEC 61850-7-1 / 7-2 Ed2.1 / 7-5/7-500

The three ctlModel issues will be addressed by 7-5/7-500 Task Force.

#6 - 05/09/2023 09:32 AM - Carlos Rodriguez del Castillo

- *Needs More Information set to No*

#7 - 05/09/2023 09:33 AM - Carlos Rodriguez del Castillo

- *Discuss in Upcoming Meeting changed from No to Yes*

#8 - 06/05/2023 01:58 AM - Carlos Rodriguez del Castillo

- *Discuss in Upcoming Meeting changed from Yes to No*

#10 - 06/14/2023 08:18 AM - Vladan Cvejic

- *Copied to IEC61850-7-5 #6382: Clarification on the ctlModel 1/3 added*