

IEC 61850 User Feedback Task Force - Feature #5080

Clarification on the ctlModel 3/3

09/20/2021 08:33 AM - Carlos Rodriguez del Castillo

Status:	Resolved	Start date:	09/20/2021
Priority:	Normal	Due date:	01/20/2022
Assignee:		% Done:	0%
Category:	Standard clarification required	Estimated time:	0.00 hour
Target version:		To discuss in WG10:	No
ID:	4	Short Proposal:	
Source:	MH	Standard(s):	IEC 61850-7-1 Ed2.1 ,7-500
TF Unique ID:	4 # MH	Needs More Information:	No
WG10 Proposal:		Assigned TF:	
Estimated Completion:			
Discuss in Upcoming Meeting:	No		
Description			
Add a statement about the use of the 'ctlModel' that it is applicable for XCBR.Pos when subscribing to CSWI.Sel* and CSWI.Op*, but is bypassed when subscribing to PTRC.Tr . Note that both the Operate and the trip are of CDC ACT.			
Proposal descriptions			
Statement is needed in the standard (7-1 or 7-2 maybe) to be able to hace ctlModel in XCBR but bypassing it by PTRC.Tr. We need a statement that direct suscription bypasses control model.			
Related issues:			
Related to IEC 61850 User Feedback Task Force - Feature #5078: Clarification ...		Resolved	09/20/2021 01/20/2022
Copied to 61850-7-5 and 61850-7-500 - IEC61850-7-5 #6379: Clarification on th...		New	09/20/2021 01/20/2022

History

#1 - 11/23/2021 09:17 AM - Carlos Rodriguez del Castillo

- Status changed from New to In Progress
- Discuss in Upcoming Meeting changed from Yes to No
- Proposal descriptions updated
- To discuss in WG10 changed from No to Yes

Statement is needed in the standard (7-1 or 7-2 maybe) to be able to hace ctlModel in XCBR but bypassing it by PTRC.Tr. We need a statement that direct suscription bypasses control model.

#2 - 02/01/2022 08:53 AM - Vladan Cvejic

- Related to Feature #5078: Clarification on the ctlModel 1/3 added

#3 - 02/09/2022 07:16 AM - Vladan Cvejic

- Status changed from In Progress to Resolved
- To discuss in WG10 changed from Yes to No

#4 - 02/14/2022 04:00 AM - Tom Berry

- Standard(s) changed from IEC 61850-7-1 Ed2.1 to IEC 61850-7-1 Ed2.1 ,7-500

#5 - 05/09/2023 09:32 AM - Carlos Rodriguez del Castillo

- Needs More Information set to No

#6 - 05/09/2023 09:33 AM - Carlos Rodriguez del Castillo

- Discuss in Upcoming Meeting changed from No to Yes

#7 - 06/05/2023 01:58 AM - Carlos Rodriguez del Castillo

- Discuss in Upcoming Meeting changed from Yes to No

#8 - 06/14/2023 08:17 AM - Vladan Cvejic

- Copied to IEC61850-7-5 #6379: Clarification on the ctiModel 3/3 added