

IEC 61850 User Feedback Task Force - Feature #5086

Clarifications on the local/remote concept 6/8

09/20/2021 08:51 AM - Carlos Rodriguez del Castillo

Status: Resolved	Start date: 09/20/2021
Priority: Normal	Due date: 01/20/2022
Assignee: Tom Berry	% Done: 0%
Category: Standard clarification required	Estimated time: 0.00 hour
Target version:	
ID: 10	To discuss in WG10: No
Source: MH	Short Proposal:
TF Unique ID: 10 # MH	Standard(s): IEC 61850-7-4 Ed2.1 ,7-5
WG10 Proposal:	Needs More Information: No
Estimated Completion:	Assigned TF:
Discuss in Upcoming Meeting: No	
Description Add a statement in the description text of 'SwModKey' that this setting effects all contained CSWI LN instances of that LD. Is the dependency of 'SwModKey' limited to contained CSWI LN instances of that LD or, in the case of nested LD, including also subordinate levels?	
Related issues:	
Related to IEC 61850 User Feedback Task Force - Feature #5081: Clarifications...	Resolved 09/20/2021
Copied to 61850-7-5 and 61850-7-500 - IEC61850-7-5 #6392: Clarifications on t...	In Progress 09/20/2021 01/20/2022

History

#1 - 02/01/2022 08:18 AM - Vladan Cvejic

- Related to Feature #5081: Clarifications on the local/remote concept 1/8 added

#2 - 02/01/2022 09:06 AM - Vladan Cvejic

- Status changed from New to In Progress

#3 - 02/09/2022 07:17 AM - Vladan Cvejic

- Status changed from In Progress to Resolved

- Discuss in Upcoming Meeting changed from Yes to No

#4 - 02/10/2022 05:52 AM - Tom Berry

Draft proposal

When there are nested logical devices, the control service checks for SwModKey should be similar to the checks for Mod/Beh.

When a control request is received at a Logical Node, the checks should take into account the status of the SwModKey data object of the logical node, and also the SwModKey data object of the LLN0 for all containing logical devices.

In the case of different values, "SwModKey=false" is dominant i.e. interlocking checks are made

#5 - 02/14/2022 02:50 AM - Carlos Rodriguez del Castillo

- Assignee set to Tom Berry

#6 - 02/14/2022 03:56 AM - Tom Berry

- Standard(s) changed from IEC 61850-7-4 Ed2.1 to IEC 61850-7-4 Ed2.1 ,7-5

#7 - 05/09/2023 09:32 AM - Carlos Rodriguez del Castillo

- Needs More Information set to No

#8 - 05/09/2023 09:33 AM - Carlos Rodriguez del Castillo

- *Discuss in Upcoming Meeting changed from No to Yes*

#9 - 06/05/2023 01:58 AM - Carlos Rodriguez del Castillo

- *Discuss in Upcoming Meeting changed from Yes to No*

#10 - 06/14/2023 08:22 AM - Vladan Cvejic

- *Copied to IEC61850-7-5 #6392: Clarifications on the local/remote concept 6/8 added*