

IEC 61850 Certificate - IEC 61850 Certificate #5114

APCG-42 Data Concentrator/RTU [Ashida Electronics Pvt. Ltd.]

10/29/2021 09:34 AM - Bruce Muschlitz

Status:	Approved	Test Document:	
Priority:	Normal	Certificate Name:	10306265-INC 21-3377
61850 Edition:	Edition 2	Certificate Hash:	EE6AB8D0310639CDD868A1F5BB44 C1ED1BAF24686920696E0CCC1FDA9 1973E6
61850 Tested Aspects:	Client	Vendor Artifact File Name:	
Company:	Ashida Electronics Pvt. Ltd.	Vendor Artifact Hash:	
Address:	Plot No.A 308, Road No.21 MIDC,Wagle Industrial Estate Thane(W) 400604 India	Umbrella Organization:	Ashida
Product:	APCG-42 Data Concentrator/RTU	Optional Reservation Test:	Yes
HW Version:		Serial Number:	
SW Version:	1.4.59 ; IEC 61850 client version: 2.1.7.2	Publisher Legacy Variants:	
Key Words:	Comm, RTU	Publisher Preferred Rates:	
Test Procedure Version:	1.2	Publisher Preferred Variants:	
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Sets (B2), Direct Control (12a), Enhanced Direct Control (12c), Enhanced SBO Control (12d), SBO Control (12b), Time Synchronization (B13), Unbuffered Reporting (B5)	Subscriber Legacy Variants:	
Certificate/Result Reviewer:	Bruce.Muschlitz	Subscriber Preferred Variants:	
Approval Date:	10/20/2021	Subscriber Preferred Rates:	
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
Current Test Lab Name:	DNV Netherlands (A)		
Description			

Files

21-3377_DNV_Ashida Electronics Ltd_APCG-42_clientEd2_Certificate.pdf 109 KB

10/29/2021

Bruce Muschlitz