

IEC 61850 Certificate - IEC 61850 Certificate #5115

TESLA 4000 [M/s. Phase Power Protection Private Limited]

11/03/2021 04:15 PM - Bruce Muschlitz

Status:	Approved	
Priority:	Normal	
61850 Edition:	Edition 2	Certificate Name: CPRIBLRMUADSASL21TC0003
61850 Tested Aspects:	Server	Certificate Hash: 62F769104A69C7CA954DDB5316AD2C7F38CD0EE02FB938614FB00005CD901AA0
Company:	M/s. Phase Power Protection Private Limited	Vendor Artifact File Name:
Address:	No.235-O/2, Second Floor, Bommasandra Industrial Area, Phase 111, Hosur Road, Bangalore-560099 INDIA	Vendor Artifact Hash:
Product:	TESLA 4000	Umbrella Organization: ERLPhase
HW Version:	2.0	Optional Reservation Test: No
SW Version:	1.2A	Serial Number:
Key Words:	Measurement	Publisher Legacy Variants:
Test Procedure Version:	2.0.5	Publisher Preferred Rates:
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Sets (B2), File Transfer (B14), GOOSE Publish (9a), GOOSE Subscribe (9b), Time Synchronization (B13), Unbuffered Reporting (B5)	Publisher Preferred Variants:
Certificate/Result Reviewer:	Bruce.Muschlitz	Subscriber Legacy Variants:
Approval Date:	11/01/2021	Subscriber Preferred Variants:
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1	Subscriber Preferred Rates:
Current Test Lab Name:	Central Power Research Institute India (A)	Product Variants:
Test Document:		Time Activated Control:
Description POWER SYSTEM RECORDER		

Files

Phase Power Protection Pvt Ltd_CPRIBLRMUADSASL21TC0003.pdf 874 KB

11/03/2021

Bruce Muschlitz