

IEC 61850 Certificate - IEC 61850 Certificate #5116

ENIP-2-45/100-220-A2E4x2-21 [Engineering Center Energoservice]

11/05/2021 12:02 PM - Bruce Muschlitz

Status:	Approved	Test Document:	
Priority:	Normal	Certificate Name:	10311750-INC 21-3368
61850 Edition:	Edition 2	Certificate Hash:	CC734CA652895E6EC9D4849B3830B3 1BF3A634EDFEC1A5357A0B56BBEAF 4280A
61850 Tested Aspects:	Server	Vendor Artifact File Name:	
Company:	Engineering Center Energoservice	Vendor Artifact Hash:	
Address:	44, Aviamotornaya street, Bld 1 Office 1A, Room 1 Moscow, 111024 Russian Federation	Umbrella Organization:	
Product:	ENIP-2-45/100-220-A2E4x2-21	Optional Reservation Test:	No
HW Version:	5.1	Serial Number:	
SW Version:	2.8.0.9	Publisher Legacy Variants:	
Key Words:	Measurement	Publisher Preferred Rates:	
Test Procedure Version:	2.0.5	Publisher Preferred Variants:	
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Set Definition (B2+), Data Sets (B2), Direct Control (12a), Enhanced SBO Control (12d), GOOSE Publish (9a), GOOSE Subscribe (9b), Time Synchronization (B13), Unbuffered Reporting (B5)	Subscriber Legacy Variants:	
Certificate/Result Reviewer:	Bruce.Muschlitz	Subscriber Preferred Variants:	
Approval Date:	10/20/2021	Subscriber Preferred Rates:	
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
Current Test Lab Name:	DNV Netherlands (A)		
Description			
Multifunctional measuring transducer With IO Module ENMV-1			

Files

21-3368_DNV_ENERGOSERVICE_ENIP-2_ServerEd2_Certificate.pdf 132 KB

11/05/2021

Bruce Muschlitz