

IEC 61850 Certificate - IEC 61850 Certificate #5117

ProField-HE Substation Automation Gateway [Prolan Power Zrt]

11/08/2021 12:45 PM - Bruce Muschlitz

Status:	Approved	Test Document:	
Priority:	Normal	Certificate Name:	10298176-INC 21-3448
61850 Edition:	Edition 2	Certificate Hash:	D10F8D4632D017E4CEC94C2B60460D 78E8AB4F09757CB745F0C42CD594B6 55E7
61850 Tested Aspects:	Client	Vendor Artifact File Name:	
Company:	Prolan Power Zrt	Vendor Artifact Hash:	
Address:	Szentendrei ut 1-3 2011 Budakalasz Hungary	Umbrella Organization:	Prolan
Product:	ProField-HE Substation Automation Gateway	Optional Reservation Test:	Yes
HW Version:		Serial Number:	
SW Version:	IMG 2.1.0 ; IEC 61850 version: SAG 4.1.0	Publisher Legacy Variants:	
Key Words:	Gateway	Publisher Preferred Rates:	
Test Procedure Version:	1.2	Publisher Preferred Variants:	
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Sets (B2), Direct Control (12a), Enhanced Direct Control (12c), Enhanced SBO Control (12d), File Transfer (B14), SBO Control (12b), Service Tracking (B15), Time Synchronization (B13), Unbuffered Reporting (B5)	Subscriber Legacy Variants:	
Certificate/Result Reviewer:	Bruce.Muschlitz	Subscriber Preferred Variants:	
Approval Date:	10/25/2021	Subscriber Preferred Rates:	
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
Current Test Lab Name:	DNV Netherlands (A)		
Description			

Files

21-3448_DNV_Prolan_ProfieldHE_ClientEd2_Certificate.pdf	117 KB	11/08/2021	Bruce Muschlitz
---	--------	------------	-----------------