

IEC 61850 Certificate - IEC 61850 Certificate #5118

TwinCarp [Hsiang Cheng Electric Corp]

11/10/2021 10:34 AM - Bruce Muschlitz

Status:	Approved	Test Document:	
Priority:	Normal	Certificate Name:	21-04-CAV-008-02
61850 Edition:	Edition 2	Certificate Hash:	381667C6E5AD802996CD42AEC93BF0 79E63901D47ABEFC3F0BD48903A2AA CE89
61850 Tested Aspects:	Client	Vendor Artifact File Name:	
Company:	Hsiang Cheng Electric Corp	Vendor Artifact Hash:	
Address:	Address 4F., No.11, Ln. 235, Baoqiao Rd., Xindian Dist., New Taipei City 231, Taiwan	Umbrella Organization:	Hsiang Cheng
Product:	TwinCarp	Optional Reservation Test:	No
HW Version:		Serial Number:	
SW Version:	V1.10	Publisher Legacy Variants:	
Key Words:	Comm, HMI	Publisher Preferred Rates:	
Test Procedure Version:	1.2	Publisher Preferred Variants:	
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Set Definition (B2+), Data Sets (B2), Direct Control (12a), Enhanced Direct Control (12c), Enhanced SBO Control (12d), File Transfer (B14), SBO Control (12b), Setting Group (B4), Setting Group Definition (B4+), Substitution (B3), Time Synchronization (B13), Unbuffered Reporting (B5)	Subscriber Legacy Variants:	
Certificate/Result Reviewer:	Bruce.Muschlitz	Subscriber Preferred Variants:	
Approval Date:	11/08/2021	Subscriber Preferred Rates:	
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
Current Test Lab Name:	Taiwan Testing and Certification Center (A)		
Description			

Files

21-04-CAV-008-02 TwinCarp IEC 61850 Client_Certificate_TP1-2.pdf 1.23 MB

11/10/2021

Bruce Muschlitz