

# IEC 61850 Certificate - IEC 61850 Certificate #5128

## WCB-822C [XJ Electric Co., Ltd.]

11/30/2021 04:31 PM - Bruce Muschlitz

<b>Status:</b>	Approved	<b>Test Document:</b>	
<b>Priority:</b>	Normal	<b>Certificate Name:</b>	D 111195 0006 Rev. 00
<b>61850 Edition:</b>	Edition 2	<b>Certificate Hash:</b>	SHA256: C407530A85209F90FB325BEF5661B60 4202A023F0BF2E74245243D84A7CD1 176
<b>61850 Tested Aspects:</b>	Server	<b>Vendor Artifact File Name:</b>	
<b>Company:</b>	XJ Electric Co., Ltd.	<b>Vendor Artifact Hash:</b>	
<b>Address:</b>	No. 1298 Xuji Avenue, 461000 Xuchang, Henan Province, People's Republic of China	<b>Umbrella Organization:</b>	XJ Electric
<b>Product:</b>	WCB-822C	<b>Optional Reservation Test:</b>	No
<b>HW Version:</b>		<b>Serial Number:</b>	
<b>SW Version:</b>	1.0	<b>Publisher Legacy Variants:</b>	
<b>Key Words:</b>	Protection, Relay	<b>Publisher Preferred Rates:</b>	
<b>Test Procedure Version:</b>	2.0.5	<b>Publisher Preferred Variants:</b>	
<b>IEC 61850 Blocks Certified:</b>	Basic Exchange (B1), Buffered Reporting (B6), Data Sets (B2), Direct Control (12a), Enhanced SBO Control (12d), File Transfer (B14), Logging (B7), Setting Group (B4), Setting Group Definition (B4+), Substitution (B3), Time Synchronization (B13), Unbuffered Reporting (B5)	<b>Subscriber Legacy Variants:</b>	
<b>Certificate/Result Reviewer:</b>	Bruce.Muschlitz	<b>Subscriber Preferred Variants:</b>	
<b>Approval Date:</b>	11/19/2021	<b>Subscriber Preferred Rates:</b>	
<b>Standards Tested:</b>	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
<b>Current Test Lab Name:</b>	TUV SUD China Ltd (A)		
<b>Description</b>			
Protection Measurement & Control Device			

### Files

21-D 111195 0006-XJ\_WCB-822C\_IEC61850Ed2-Server-Certificate.pdf 804 KB

11/30/2021

Bruce Muschlitz