

IEC 61850 Certificate - IEC 61850 Certificate #5129

WXH-803 [XJ Electric Co., Ltd.]

11/30/2021 04:37 PM - Bruce Muschlitz

Status:	Approved	Test Document:	
Priority:	Normal	Certificate Name:	D 111195 0009 Rev. 00
61850 Edition:	Edition 2	Certificate Hash:	SHA256: 7CF6679A48887E67974B32E1E7B59C BC1B0A34314F875EB301D62A5DEDE5 0ECDD
61850 Tested Aspects:	Server	Vendor Artifact File Name:	
Company:	XJ Electric Co., Ltd.	Vendor Artifact Hash:	
Address:	No. 1298 Xuji Avenue, 461000 Xuchang, Henan Province, People's Republic of China	Umbrella Organization:	XJ Electric
Product:	WXH-803	Optional Reservation Test:	No
HW Version:		Serial Number:	
SW Version:	4.0	Publisher Legacy Variants:	
Key Words:	Differential, Protection, Relay	Publisher Preferred Rates:	
Test Procedure Version:		Publisher Preferred Variants:	
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Sets (B2), Direct Control (12a), Enhanced SBO Control (12d), File Transfer (B14), Logging (B7), Setting Group (B4), Setting Group Definition (B4+), Substitution (B3), Time Synchronization (B13), Unbuffered Reporting (B5)	Subscriber Legacy Variants:	
Certificate/Result Reviewer:	Bruce.Muschlitz	Subscriber Preferred Variants:	
Approval Date:	11/19/2021	Subscriber Preferred Rates:	
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
Current Test Lab Name:	TUV SUD China Ltd (A)		
Description			
Line Differential Relay			

Files

21-D 111195 0009-XJ_WXH-803_IEC61850Ed2-Server-Certificate.pdf 303 KB

11/30/2021

Bruce Muschlitz