

IEC 61850 Certificate - IEC 61850 Certificate #5132

BIM 2235.89.16/16 ADP01 [STC GOSAN Ltd.]

12/06/2021 02:59 PM - Bruce Muschlitz

Status:	Approved	Test Document:	
Priority:	Normal	Certificate Name:	10320627-INC 21-3480
61850 Edition:	Edition 2	Certificate Hash:	SHA256: 0A45919ED31A958BF89C1C3D677A16 56F5FE920F633A5B6BEFC247D49259 63E5
61850 Tested Aspects:	Server	Vendor Artifact File Name:	
Company:	STC GOSAN Ltd.	Vendor Artifact Hash:	
Address:	Stroitel'nyi dvor Biorki poselok Kolomenskii r-n Moscow Region 140452 Russian Federation	Umbrella Organization:	GOSAN
Product:	BIM 2235.89.16/16 ADP01	Optional Reservation Test:	No
HW Version:		Serial Number:	
SW Version:	Software: B0.66; Firmware: 03.23.0004	Publisher Legacy Variants:	
Key Words:	Bay Controller	Publisher Preferred Rates:	
Test Procedure Version:	2.0.4	Publisher Preferred Variants:	
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Sets (B2), Direct Control (12a), Enhanced SBO Control (12d), File Transfer (B14), GOOSE Publish (9a), GOOSE Subscribe (9b), Setting Group (B4), Setting Group Definition (B4+), Time Synchronization (B13), Unbuffered Reporting (B5)	Subscriber Legacy Variants:	
Certificate/Result Reviewer:	Bruce.Muschlitz	Subscriber Preferred Variants:	
Approval Date:	11/12/2021	Subscriber Preferred Rates:	
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
Current Test Lab Name:	DNV Netherlands (A)		
Description Bay Controller			

History

#1 - 12/06/2021 03:02 PM - Bruce Muschlitz

- IEC 61850 Blocks Certified Buffered Reporting (B6), Data Sets (B2), Direct Control (12a), Enhanced SBO Control (12d), File Transfer (B14), GOOSE Publish (9a), GOOSE Subscribe (9b), Setting Group (B4), Setting Group Definition (B4+), Time Synchronization (B13), Unbuffered Reporting (B5) added

#2 - 12/06/2021 03:02 PM - Bruce Muschlitz

- File 21-3480_DNV_GOSAN_BIM_2235.89.16_16_ADP01_ServerEd2_Certificate.pdf added

Files

