

IEC 61850 Certificate - IEC 61850 Certificate #5134

P0101 [NIPOM]

12/06/2021 03:16 PM - Bruce Muschlitz

Status:	Approved	Test Document:	
Priority:	Normal	Certificate Name:	10320627-INC 21-3483
61850 Edition:	Edition 2	Certificate Hash:	SHA256: 92DBE5CBEA034ACEF99ADBEBCC4B E0D01910276D5A458A6EEA0417541C BF481C
61850 Tested Aspects:	Server	Vendor Artifact File Name:	
Company:	NIPOM	Vendor Artifact Hash:	
Address:	Zelenaya Street, 10, Dzerzhinsk Nizhny Novgorod Region, 606000 Russian Federation	Umbrella Organization:	NiPOM
Product:	P0101	Optional Reservation Test:	No
HW Version:	3433-024-57170176-2018	Serial Number:	
SW Version:	3.02	Publisher Legacy Variants:	
Key Words:	Protection, Relay	Publisher Preferred Rates:	
Test Procedure Version:	2.0.4	Publisher Preferred Variants:	
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Set Definition (B2+), Data Sets (B2), Direct Control (12a), File Transfer (B14), GOOSE Publish (9a), GOOSE Subscribe (9b), Setting Group (B4), Setting Group Definition (B4+), Time Synchronization (B13), Unbuffered Reporting (B5)	Subscriber Legacy Variants:	
Certificate/Result Reviewer:	Bruce.Muschlitz	Subscriber Preferred Variants:	
Approval Date:	11/18/2021	Subscriber Preferred Rates:	
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
Current Test Lab Name:	DNV Netherlands (A)		
Description			
Low-voltage device for microprocessor relay protection and automation 110-220 kV			

Files

21-3483_DNV_NIPOM_P0101_ServerEd2_Certificate.pdf	117 KB	12/06/2021	Bruce Muschlitz
---	--------	------------	-----------------