

# IEC 61850 Certificate - IEC 61850 Certificate #5135

## TOPAZ DRP-35 [PLC Technology]

12/06/2021 03:22 PM - Bruce Muschlitz

<p><b>Status:</b> Approved</p> <p><b>Priority:</b> Normal</p> <p><b>61850 Edition:</b> Edition 2</p> <p><b>61850 Tested Aspects:</b> Server</p> <p><b>Company:</b> PLC Technology</p> <p><b>Address:</b> 117449 Vinokurova st.3 Moscow Russian Federation</p> <p><b>Product:</b> TOPAZ DRP-35</p> <p><b>HW Version:</b></p> <p><b>SW Version:</b> TOPAZ LINUX 1.0</p> <p><b>Key Words:</b></p> <p><b>Test Procedure Version:</b> 2.0.4</p> <p><b>IEC 61850 Blocks Certified:</b> Basic Exchange (B1), Buffered Reporting (B6), Data Sets (B2), Direct Control (12a), Enhanced SBO Control (12d), File Transfer (B14), GOOSE Publish (9a), GOOSE Subscribe (9b), Setting Group (B4), Setting Group Definition (B4+), Time Synchronization (B13), Unbuffered Reporting (B5)</p> <p><b>Certificate/Result Reviewer:</b> Bruce.Muschlitz</p> <p><b>Approval Date:</b> 11/19/2021</p> <p><b>Standards Tested:</b> 61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1</p> <p><b>Current Test Lab Name:</b> DNV Netherlands (A)</p>	<p><b>Test Document:</b></p> <p><b>Certificate Name:</b> 10320627-DSO 21-3548</p> <p><b>Certificate Hash:</b> SHA256: 321051A88836F5DEB4634DEF024E472 F7A9CAA3F951184E582E0FDD396644 E7C</p> <p><b>Vendor Artifact File Name:</b></p> <p><b>Vendor Artifact Hash:</b></p> <p><b>Umbrella Organization:</b> PLC Technology</p> <p><b>Optional Reservation Test:</b> No</p> <p><b>Serial Number:</b></p> <p><b>Publisher Legacy Variants:</b></p> <p><b>Publisher Preferred Rates:</b></p> <p><b>Publisher Preferred Variants:</b></p> <p><b>Subscriber Legacy Variants:</b></p> <p><b>Subscriber Preferred Variants:</b></p> <p><b>Subscriber Preferred Rates:</b></p>
<p><b>Description</b></p>	

### Files

21-3548\_DNV\_PLCTechnology\_TOPAZ-DRP-35\_ServerEd2\_Certificate.pdf 17KB

12/06/2021

Bruce Muschlitz