

IEC 61850 Certificate - IEC 61850 Certificate #5136

SAMU-1000 [KEPCO KDN]

12/08/2021 02:01 PM - Bruce Muschlitz

Status:	Approved	Test Document:	
Priority:	Normal	Certificate Name:	21TC200802
61850 Edition:	Edition 1	Certificate Hash:	SHA256: 19D5FA8F830B6902FB92CC6905817F 2505DD174D940AB4355B8A8239ECE2 C7F4
61850 Tested Aspects:	Merging Unit	Vendor Artifact File Name:	
Company:	KEPCO KDN	Vendor Artifact Hash:	
Address:	661 Bitgaram-ro, Naju-si, Jeollanam-do, Republic of Korea	Umbrella Organization:	KEPCO
Product:	SAMU-1000	Optional Reservation Test:	No
HW Version:	1.0	Serial Number:	
SW Version:	1.0	Publisher Legacy Variants:	F12800S8I4U4, F15360S8I4U4, F4000S1I4U4, F4800S1I4U4
Key Words:	Merging Unit	Publisher Preferred Rates:	
Test Procedure Version:	1.1 with TPCL 1.1	Publisher Preferred Variants:	
IEC 61850 Blocks Certified:	Sampled Value Publish (11a)	Subscriber Legacy Variants:	
Certificate/Result Reviewer:	Bruce.Muschlitz	Subscriber Preferred Variants:	
Approval Date:	12/02/2021	Subscriber Preferred Rates:	
Standards Tested:	61850-6, 61850-7-2, 61850-9-2, UCAIug 9-2LE		
Current Test Lab Name:	Korea Electrotechnology Research Institute (A)		
Description			
Merging Unit			
3 phase voltage and 6 phase current Neutral is calculated			

History

#1 - 12/08/2021 02:14 PM - Bruce Muschlitz

- Description updated

- Standards Tested UCAIug 9-2LE added

#2 - 06/13/2022 05:09 PM - Bruce Muschlitz

- Publisher Legacy Variants F12800S8I4U4, F15360S8I4U4, F4000S1I4U4, F4800S1I4U4 added

Files

21TC200802_KEPCOKDN_SAMU-1000_SV_Ed1_KERI_R1.pdf	214 KB	12/08/2021	Bruce Muschlitz
--	--------	------------	-----------------