

IEC 61850 Certificate - IEC 61850 Certificate #5139

saTECH SCU-HMI 122 [Arteche/SAC]

12/13/2021 09:41 AM - Bruce Muschlitz

Status:	Approved	Test Document:	
Priority:	Normal	Certificate Name:	10301316-INC 21-3541
61850 Edition:	Edition 2	Certificate Hash:	SHA256: AB5271EFC55AD35188A51AF04969C8 F946BE5793032CD5A5231866B713BA 8283
61850 Tested Aspects:	Server	Vendor Artifact File Name:	
Company:	Arteche/SAC	Vendor Artifact Hash:	
Address:	Derio Bidea 28, Zabalondo Industrialdea 48100 Mungia, Bizkaia Spain	Umbrella Organization:	Arteche
Product:	saTECH SCU-HMI 122	Optional Reservation Test:	No
HW Version:		Serial Number:	
SW Version:	V.2.1.2	Publisher Legacy Variants:	
Key Words:	Comm, Gateway, HMI, RTU	Publisher Preferred Rates:	
Test Procedure Version:	2.0.5	Publisher Preferred Variants:	
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Sets (B2), Direct Control (12a), Enhanced Direct Control (12c), Enhanced SBO Control (12d), GOOSE Publish (9a), SBO Control (12b), Time Synchronization (B13), Unbuffered Reporting (B5)	Subscriber Legacy Variants:	
Certificate/Result Reviewer:	Bruce.Muschlitz	Subscriber Preferred Variants:	
Approval Date:	11/25/2021	Subscriber Preferred Rates:	
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
Current Test Lab Name:	DNV Netherlands (A)		
Description			

Files

21-3541_DNV_Arteche SAC_saTECH-SCU-HMI 122_ServerEd2_Certificate.pdf

12/13/2021

Bruce Muschlitz