

IEC 61850 Certificate - IEC 61850 Certificate #5144

SM160-02M/D [Prompribor Plant Limited]

12/14/2021 11:50 AM - Bruce Muschlitz

Status:	Approved	Test Document:	
Priority:	Normal	Certificate Name:	10320627 -INC 21-3505.Rev2
61850 Edition:	Edition 2	Certificate Hash:	SHA256: B7098A515D134752ED4EB53BE88F49 D8A82F9FDD6C4F082527A50FF4BD83 3464
61850 Tested Aspects:	Server	Vendor Artifact File Name:	
Company:	Prompribor Plant Limited	Vendor Artifact Hash:	
Address:	8 Lakina St, room 59 Vladimir, Vladimir Region Russian Federation	Umbrella Organization:	Prompribor
Product:	SM160-02M/D	Optional Reservation Test:	No
HW Version:	VLST 340.00.000.02M	Serial Number:	
SW Version:	1.9.2.3144	Publisher Legacy Variants:	
Key Words:	RTU	Publisher Preferred Rates:	
Test Procedure Version:	2.0.4	Publisher Preferred Variants:	
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Set Definition (B2+), Data Sets (B2), Direct Control (12a), GOOSE Publish (9a), GOOSE Subscribe (9b), Time Synchronization (B13), Unbuffered Reporting (B5)	Subscriber Legacy Variants:	
Certificate/Result Reviewer:	Bruce.Muschlitz	Subscriber Preferred Variants:	
Approval Date:	12/03/2021	Subscriber Preferred Rates:	
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
Current Test Lab Name:	DNV Netherlands (A)		
Description			
Intelligent controller			

History

#1 - 12/14/2021 11:52 AM - Bruce Muschlitz

- Test Procedure Version set to 2.0.4

#2 - 12/15/2021 10:56 AM - Bruce Muschlitz

- File deleted (21-3505_DNV_PROMPRIBOR PLANT LIMITED_SM160-02M_ServerEd2_Certificate.pdf)

#3 - 12/15/2021 10:59 AM - Bruce Muschlitz

- File 21-3505_DNV_PROMPRIBOR PLANT LIMITED_SM160-02M_ServerEd2_Certificate.pdf added

- Description updated

- Certificate Name changed from 10320627 -INC 21-3505.Rev1 to 10320627 -INC 21-3505.Rev2

- Certificate Hash changed from SHA256: E4585CDB9407E687CCC98D0DB828944A24A04372803EC663CD807FE797AF674E to SHA256:

Files

21-3505_DNV_PROMPRIBOR PLANT LIMITED_SM160-02M_ServerEtc_Certificate.pdf 12/15/2021

Bruce Muschlitz