

IEC 61850 Certificate - IEC 61850 Certificate #5146

SIPROTEC 5 Compact 7SX800 [Siemens AG]

12/14/2021 04:16 PM - Bruce Muschlitz

Status:	Approved	Test Document:	
Priority:	Normal	Certificate Name:	10300967-INC 21-3332
61850 Edition:	Edition 2 Amd 1	Certificate Hash:	SHA256: 0B0772C06021831C71841CD318EB5A 7492FCC437AF0DD6ED66A0B06FC62 02ACE
61850 Tested Aspects:	Server	Vendor Artifact File Name:	
Company:	Siemens AG	Vendor Artifact Hash:	
Address:	Wernerwerkdammm 5 13629 Berlin Germany	Umbrella Organization:	Siemens
Product:	SIPROTEC 5 Compact 7SX800	Optional Reservation Test:	No
HW Version:	7SX8000-3BA50-1CA0	Serial Number:	
SW Version:	V08.82	Publisher Legacy Variants:	
Key Words:	Protection, Relay	Publisher Preferred Rates:	
Test Procedure Version:	1.1	Publisher Preferred Variants:	
IEC 61850 Blocks Certified:	Basic Exchange (B1 a), Buffered Reporting (B6), Data Set Definition (B2+), Data Sets (B2), Direct Control (12a), Enhanced Direct Control (12c), Enhanced SBO Control (12d), File Transfer (B14), GOOSE Publish (9a), GOOSE Subscribe (9b), SBO Control (12b), Service Tracking (B15), Setting Group (B4), Setting Group Definition (B4+), Substitution (B3), Time sync SNTP (B13a), Unbuffered Reporting (B5)	Subscriber Legacy Variants:	
Certificate/Result Reviewer:	Bruce.Muschlitz	Subscriber Preferred Variants:	
Approval Date:	12/09/2021	Subscriber Preferred Rates:	
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
Current Test Lab Name:	DNV Netherlands (A)		
Description			
Universal protection relay			

History

#1 - 12/15/2021 01:51 PM - Bruce Muschlitz

- Current Test Lab Name set to DNV Netherlands (A)

#2 - 12/17/2021 02:16 PM - Herbert Falk

- IEC 61850 Blocks Certified Basic Exchange (B1a), Time sync SNTP (B13a) added

- IEC 61850 Blocks Certified deleted (Basic Exchange (B1), Time Synchronization (B13))

Files

21-3332_DNV_Siemens_7SX800_ServerEd2Amd1_Certificate.pdf	116 KB	12/14/2021	Bruce Muschlitz
--	--------	------------	-----------------