

IEC 61850 Certificate - IEC 61850 Certificate #5148

SIPROTEC 5 7SJ82 with variants [Siemens AG]

12/15/2021 01:50 PM - Bruce Muschlitz

Status:	Approved	Test Document:	
Priority:	Normal	Certificate Name:	10300967-INC 21-3341
61850 Edition:	Edition 2 Amd 1	Certificate Hash:	SHA256: 951C77C17E8D491C9F94475A85F0A5 CAB2644AB62186B89654A6C17E8325 DFE2
61850 Tested Aspects:	Server	Vendor Artifact File Name:	
Company:	Siemens AG	Vendor Artifact Hash:	
Address:	Wernerwerkdamm 5 13629 Berlin Germany	Umbrella Organization:	Siemens
Product:	SIPROTEC 5 7SJ82 with variants	Optional Reservation Test:	No
HW Version:	7SJ82-DAAA-AA0-0AAAAA0-A90411-131 13A-EBA000-000AB0-HB1BD4-JA0	Serial Number:	
SW Version:	V08.82	Publisher Legacy Variants:	
Key Words:	IOC, Protection, Relay, TOC	Publisher Preferred Rates:	
Test Procedure Version:	1.1	Publisher Preferred Variants:	
IEC 61850 Blocks Certified:	Basic Exchange (B1a), Buffered Reporting (B6), Data Set Definition (B2+), Data Sets (B2), Direct Control (12a), Enhanced Direct Control (12c), Enhanced SBO Control (12d), File Transfer (B14), GOOSE Publish (9a), GOOSE Subscribe (9b), SBO Control (12b), Service Tracking (B15), Setting Group (B4), Setting Group Definition (B4+), Substitution (B3), Time sync SNTP (B13a), Unbuffered Reporting (B5)	Subscriber Legacy Variants:	
Certificate/Result Reviewer:	Bruce.Muschlitz	Subscriber Preferred Variants:	
Approval Date:	12/14/2021	Subscriber Preferred Rates:	
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
Current Test Lab Name:	DNV Netherlands (A)		
Description			

History

#1 - 12/17/2021 01:33 PM - Bruce Muschlitz

- Subject changed from SIPROTEC 5 7SJ82 [Siemens AG] to SIPROTEC 5 7SJ82 with variants [Siemens AG]

- Product changed from SIPROTEC 5 7SJ82 to SIPROTEC 5 7SJ82 with variants

#2 - 12/17/2021 02:12 PM - Herbert Falk

- IEC 61850 Blocks Certified Basic Exchange (B1a), Time sync SNTP (B13a) added

- IEC 61850 Blocks Certified deleted (Basic Exchange (B1), Time Synchronization (B13))

Files

21-3341_DNV_Siemens_7SJ82andVariants_ServerEd2Amd1_Certificate.pdf

12/15/2021

Bruce Muschlitz