

IEC 61850 Certificate - IEC 61850 Certificate #5149

ARIS-2305 [Prosoft-Systems Ltd.]

12/15/2021 02:11 PM - Bruce Muschlitz

Status:	Approved	Test Document:	
Priority:	Normal	Certificate Name:	10320627-DSO 21-3580
61850 Edition:	Edition 2	Certificate Hash:	SHA256: 0A0B7DA36F9A614A8EDFD473955E1F D321A196AD4A88027286F8EE30C798 CCC2
61850 Tested Aspects:	Server	Vendor Artifact File Name:	
Company:	Prosoft-Systems Ltd.	Vendor Artifact Hash:	
Address:	194a Volgogradskaya str. 620102 Ekaterinburg Russian Federation	Umbrella Organization:	Prosoft
Product:	ARIS-2305	Optional Reservation Test:	No
HW Version:		Serial Number:	
SW Version:	1.9.159.44220 /M1.9; IEC 61850 version: 1.0.1.4	Publisher Legacy Variants:	
Key Words:	Measurement, Protection, Relay	Publisher Preferred Rates:	
Test Procedure Version:	2.0.5	Publisher Preferred Variants:	
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Set Definition (B2+), Data Sets (B2), Direct Control (12a), Enhanced Direct Control (12c), Enhanced SBO Control (12d), File Transfer (B14), GOOSE Publish (9a), GOOSE Subscribe (9b), Setting Group (B4), Setting Group Definition (B4+), Substitution (B3), Time Synchronization (B13), Unbuffered Reporting (B5)	Subscriber Legacy Variants:	
Certificate/Result Reviewer:	Bruce.Muschlitz	Subscriber Preferred Variants:	
Approval Date:	12/02/2021	Subscriber Preferred Rates:	
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
Current Test Lab Name:	DNV Netherlands (A)		
Description			
Protection, Automation, Measurement IED			

Files

21-3580_DNV_Prosoft_ARIS-2305andVariants_ServerEd2_Certificate.pdf 20 KB

12/15/2021

Bruce Muschlitz