

## IEC 61850 User Feedback Task Force - Support #515

These test cases assume that a server will send a negative response to an operate to the same value. Some servers will accept th

02/03/2021 02:07 PM - Herbert Falk

<b>Status:</b> Closed	<b>Start date:</b>
<b>Priority:</b> Normal	<b>Due date:</b>
<b>Assignee:</b>	<b>% Done:</b> 0%
<b>Category:</b>	<b>Estimated time:</b> 0.00 hour
<b>Target version:</b>	
<b>ID:</b> 31	<b>To discuss in WG10:</b>
<b>Source:</b> IOP_2015	<b>Short Proposal:</b>
<b>TF Unique ID:</b> 31 # IOP_2015	<b>Standard(s):</b>
<b>WG10 Proposal:</b>	<b>Needs More Information:</b>
<b>Estimated Completion:</b>	<b>Assigned TF:</b>
<b>Discuss in Upcoming Meeting:</b>	
<b>Description</b>	
These test cases assume that a server will send a negative response to an operate to the same value. Some servers will accept this behavior as described in PIXIT. The goal of the test is to get a negative response, which was possible with other scenarios.	

### History

#1 - 06/21/2022 09:12 AM - Carlos Rodriguez del Castillo

- Status changed from New to Closed

Confirm to IEC 61850-6 editor that this issue has been accounted for.