

IEC 61850 Certificate - IEC 61850 Certificate #5150

ENTEK E2R2(G)-1 [ENTELS LLC]

12/15/2021 02:23 PM - Bruce Muschlitz

Status:	Approved	Test Document:	
Priority:	Normal	Certificate Name:	10320627-DSO 21-3537
61850 Edition:	Edition 2	Certificate Hash:	Size: 142065 bytes (138 KiB)
61850 Tested Aspects:	Server	Vendor Artifact File Name:	
Company:	ENTELS LLC	Vendor Artifact Hash:	
Address:	Ryabinovaya st, house 69, building 5 Moscow Russian Federation	Umbrella Organization:	ENTELS
Product:	ENTEK E2R2(G)-1	Optional Reservation Test:	No
HW Version:		Serial Number:	
SW Version:	ENLOGIC E2R2-G build 20.07.2021-VQd	Publisher Legacy Variants:	
Key Words:	RTU	Publisher Preferred Rates:	
Test Procedure Version:	2.0.4	Publisher Preferred Variants:	
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Sets (B2), Direct Control (12a), SBO Control (12b), Time Synchronization (B13), Unbuffered Reporting (B5)	Subscriber Legacy Variants:	
Certificate/Result Reviewer:	Bruce.Muschlitz	Subscriber Preferred Variants:	
Approval Date:	11/23/2021	Subscriber Preferred Rates:	
Standards Tested:	61850-8-1		
Current Test Lab Name:	DNV Netherlands (A)		
Description Gateway for collecting, storing and transmitting data			

Files

21-3537_DNV_ENTELS_KM_ENTEK E2R2(G)-1_ServerEd2_Certificate.pdf	39 KB	12/15/2021	Bruce Muschlitz
---	-------	------------	-----------------