

IEC 61850 Certificate - IEC 61850 Certificate #5152

MCS-8500 [XJ Electric Co., Ltd.]

01/05/2022 12:20 PM - Bruce Muschlitz

Status:	Approved	Test Document:	
Priority:	Normal	Certificate Name:	D 111195 0010 Rev.00
61850 Edition:	Edition 2	Certificate Hash:	SHA256: 7EBAFF4BB2CADD8BDD8B4ED2711112 6CA37B7EC6B5C1BBAEA9710A240A9 E567D8
61850 Tested Aspects:	Client	Vendor Artifact File Name:	
Company:	XJ Electric Co., Ltd.	Vendor Artifact Hash:	
Address:	No. 1298 Xuji Avenue, 461000 Xuchang, Henan Province, People's Republic of China	Umbrella Organization:	XJ Electric
Product:	MCS-8500	Optional Reservation Test:	No
HW Version:	ThinkStation P720; Processor: Intel Xeon Bronze 3204; Processor word length: 64 bits; Memory: 8G; Hard disk: 1TB; OS: Red Hat Enterprise Linux Server v6.9.	Serial Number:	
SW Version:	1.00	Publisher Legacy Variants:	
Key Words:	RTU	Publisher Preferred Rates:	
Test Procedure Version:	1.2	Publisher Preferred Variants:	
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Direct Control (12a), Enhanced Direct Control (12c), Enhanced SBO Control (12d), File Transfer (B14), SBO Control (12b), Setting Group (B4), Setting Group Definition (B4+), Substitution (B3), Time Synchronization (B13), Unbuffered Reporting (B5)	Subscriber Legacy Variants:	
Certificate/Result Reviewer:	Bruce.Muschlitz	Subscriber Preferred Variants:	
Approval Date:	12/28/2021	Subscriber Preferred Rates:	
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
Current Test Lab Name:	TUV SUD China Ltd (A)		

Description

international substation monitoring system

History

#1 - 01/05/2022 12:21 PM - Bruce Muschlitz

- Umbrella Organization set to XJ Electric

#2 - 01/16/2022 09:55 AM - Herbert Falk

- Current Test Lab Name set to TUV SUD China Ltd (A)

Files

21-D 111195 0010_XJ_MCS-8500-I_IEC61850_Client_Certificate.pdf 1.83 MB

01/05/2022

Bruce Muschlitz